

***Annual Drinking Water Quality Report for 2017***  
**Bolton Water District**  
Town of Bolton, 4949 Lake Shore Drive, Bolton Landing, NY 12814  
(Public Water Supply Identification Number NY5600101)

**INTRODUCTION**

We are very pleased to provide you with this year's Annual Drinking Water Quality Report. Last year, your drinking water met all State drinking water health standards. This report is a snapshot of last year's water quality. Included are details about where your water comes from, what it contains, and how it compares to New York State standards. Our constant goal is and always has been, to provide to you a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and to protect our water resources. If you have any questions concerning this report or concerning your drinking water please contact: *Mr. Dylan Reid (ny0040928) Operator of record, Mr. Jeffery Dickinson (ny0036645) water system operator; 459 Edgecomb Pond Road, Bolton Landing, NY 12814 Telephone (518) 644-9350 or Town Supervisor Ron Conover (518) 644-2461. Additional information may be obtained at the Town Hall or at a regularly scheduled Town Board Meeting* Board meetings are held on the first Tuesday of each month, 6:00 PM at the Town Hall, 4949 Lake Shore Drive, Bolton Landing, NY 12814; Telephone (518) 644-2461; Webpage [www.boltonnewyork.com](http://www.boltonnewyork.com)

This report is being mailed to all water district customers in the spring 2018, billing cycle. This report is also available on the Town website and at the Town Clerk's Office in the Town Hall.

**WHERE DOES OUR WATER COME FROM?**

The Town of Bolton operates a surface water filtration plant. The source of our drinking water is Edgecomb Pond. The 35 acre pond has a storage capacity of 143 million gallons of usable water confined behind a 13' high concrete dam. There are about 1,152 acres of land in the watershed, of which 300 acres or approximately 25% is owned by the Water District, including all of the Pond's shoreline. A significant portion of the watershed is now owned by the Lake George Land Conservancy. The first water district was established in 1929 to provide water to the hamlet area. A second district was added in 1948 to extend water service south on 9N. Water is pumped from Edgecomb Pond to a surface water filtration plant. The Bolton Water Treatment Plant has two rapid sand filters capable of processing a total of one (1) million gallons per day. The treatment process consists of pH adjustment using soda ash followed by coagulation using polyaluminum chloride (PAC). Polyaluminum chloride is designed to cause fine particles in the water to bind together forming larger particles, which are then trapped on the sand filters. Liquid chlorine is added as a disinfectant to protect against harmful bacteria and other organisms. We add a polyorthophosphate corrosion control compound to serve as a shield on the interior of all pipes preventing lead and copper from leaching into the water from water pipes and solders. The finished water flows by gravity to a 500,000 gallon clearwell where the pH is adjusted using soda ash to enhance the anti-corrosion treatment and then flows by gravity to the distribution system. The clearwell provides storage to meet consumer demand and provide adequate fire protection.

In general, the sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activities. Contaminants that may be present in source water include: microbial contaminants; inorganic contaminants; pesticides and herbicides; organic chemical contaminants; and radioactive contaminants. In order to ensure that tap water is safe to drink, the NYSDOH and the United States Environmental Protection Agency (USEPA) prescribe regulations which limit the amount of certain contaminants in water provided by public water systems. The State Health Departments and the FDA's regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

**FACTS AND FIGURES**

The Town provides water through 740 service connections to a population of approximately 1,800 people. Our average daily demand is 235,112 gallons. Our single highest day was 414,951 gallons. The total water produced in 2017 was 85,816,231 gallons. All water services are metered. This serves to promote water conservation and to provide a fair source of revenue. Water meter readings and billings are done on a quarterly basis- April, July, October and January. For a detailed water users rate schedule contact the Town of Bolton.

**WHAT IS THE SOURCE WATER ASSESSMENT PROGRAM (SWAP)?**

To emphasize the protection of surface and ground water sources used for public drinking water, Congress amended the Safe Drinking Water Act (SDWA) in 1996. The amendments require that New York State Department of Health's Bureau of Public Water Supply Protection is responsible for ensuring that source water assessments are completed for all of New York's public water systems. The NYSDOH has completed a Source Water Assessment Plan (SWAP) for our system, based on available information. Possible and actual threats to the drinking water source were evaluated. The SWAP includes a susceptibility rating based on the risk posed by each potential source of contamination and how

easily contaminants can move through the subsurface to the wells and surface water. The susceptibility rating is an estimate of the potential for contamination of the source water, it does not mean that the water delivered to consumers is, or will become, contaminated. The source water assessments provide resource managers with additional information for protecting source waters into the future.

The source water assessment did not identify any significant source of contamination to our water source Edgecomb Pond. There are no regulated facilities within the watershed of Edgecomb Pond, and the corresponding land cover and land uses within the assessment area do not pose any substantial threats to the source water quality. Continued vigilance in compliance with water quality protection and pollution and prevention programs as well as continued monitoring and enforcement will help to continue to protect our source water quality.

#### ARE THERE CONTAMINANTS IN OUR DRINKING WATER?

In accordance with State regulations, the Town of Bolton routinely monitors your drinking water for numerous contaminants. We test your drinking water for inorganic contaminants, radiological contaminants, lead and copper, nitrate, volatile organic contaminants, and synthetic organic contaminants. In addition, we test two (2) samples in the distribution system for coliform bacteria each month. The table presented on page 4 depicts which contaminants were detected in your drinking water. The state allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Some of the data, though representative of the water quality, is more than one year old and is noted.

It should be noted that all drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily pose a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (800-426-4791) or the New York State Department of Health Glens Falls District Office at (518) 793-3893.

#### WHAT DOES THIS INFORMATION MEAN?

As you can see by the table on page 4, our system had no violations. We have learned through our monitoring and testing that some contaminants have been detected; however, these compounds were detected below New York State requirements. MCL's are set at very stringent levels. To understand the possible health effects described for many regulated contaminants, a person would have to drink 2 liters of water every day at the MCL level for a lifetime to have a one-in-a-million chance of having the described health effect.

#### INFORMATION ON LEAD

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Bolton Water District is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>

#### IS OUR WATER SYSTEM MEETING OTHER RULES THAT GOVERN OPERATIONS?

During 2017, our system was in compliance with applicable State drinking water operating, monitoring and reporting requirements.

#### SPECIAL CONDITIONS

Although our drinking water met or exceeded state and federal regulations, some people may be more vulnerable to disease causing microorganisms or pathogens in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice from their health care provider about their drinking water. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium*, *Giardia* and other microbiological pathogens are available from the Safe Drinking Water Hotline (800-426-4791).

#### WATER CONSERVATION TIPS

The Town of Bolton encourages water conservation. There are a lot of things you can do to conserve water in your own home. Conservation tips include:

- + Only run the dishwasher and clothes washer when there is a full load
- + Use water saving showerheads
- + Install faucet aerators in the kitchen and the bathroom to reduce the flow from 4 to 2.5 gallons per minute
- + Water gardens and lawn for only a couple of hours after sunset

- + Check faucets, pipes and toilets for leaks and repair all leaks promptly
- + Take shorter showers

**CLOSING**

Our goal is to continue to furnish high quality, safe drinking water to our community. Thank you for reading the information that we have provided in the annual report. We know it is important to keep our consumers informed; we welcome your comments and suggestions.

**TOWN OF BOLTON TABLE OF DETECTED CONTAMINANTS**  
Public water supply identification number (5600101)

Contaminant	Violation Y/N	Level Detected	Unit Measurement	MCLG	MCL	Likely Source of Contamination
Total Coliform 10/18/17	N	1 sample positive	Cfu/100mL	0	MCL= 2 or more positive samples	Naturally present in the environment.
Turbidity	N	0.17 <sup>1</sup>	NTU	N/A	TT=5 NTU	Soil runoff
		100%			TT= % samples <0.3	
<b>Inorganic Contaminants</b>						
Barium 6/7/17	N	7.0	Ug/L	2000	2000	Erosion of natural deposits
Chloride 9/12/17	N	10.1	Mg/l	N/A	250	Geology; Naturally occurring
Fluoride 6/7/17	N	ND	Mg/l	N/A	2.2	Naturally occurring.
Lead (sample 9/27/15) Range of Lead concentrations	N	1 <sup>2</sup> ND-3	Ug/L	0.015	AL=15	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Copper (samples from 9/27/15) Range of cooper concentrations	N	360 <sup>2</sup> 70-370	Ug/l	1300	AL=1:300	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Manganese 9/12/17	N	8	Ug/L	N/A	300	Geology; Naturally occurring
Sodium 9/12/17	N	17	Mg/L	N/A	N/A	Geology; Road Salt
Sulfate 9/12/17	N	3.52	Mg/L		250	Geology
Zinc 9/12/17	N	369	Ug/L	N/A	5000	Galvanized pipe; Corrosion inhibitor
Arsenic 6/7/17	N	ND	Ug/L	10	10	Geology; Naturally occurring
<b>Stage 2 Disinfection Byproducts (sample data from quarterly samples collected 2/2/15, 5/19/15, 9/1/15 &amp; 11/21/15)</b>						
Haloacetic Acids (HAA5) average <sup>3</sup> Range of values for HAA5	N	32.7 21-38.5	Ug/L	N/A	60 <sup>6</sup>	By-product of drinking water chlorination.
Total Trihalomethanes (TTHM) average <sup>4</sup> Range of values for TTHM	N	29 13.4-34.6	Ug/L	0	80	By-product of drinking water chlorination
Chlorine Residual average based on (daily testing) Range of values	N	1.16 0.90-1.33	ppm	MRDLG N/A	MRDL 4	Used in the treatment and disinfection of drinking water

**NOTES-**

1. Turbidity is a measure of the cloudiness of the water. We monitor it because it is a good indicator of the effectiveness of our filtration system. The level detected represents the highest level detected. Distribution system turbidity performed 7 times a week with 0.17 NTU being the average level detected with 1.43 NTU being highest level detected and .076 NTU being the lowest level detected.
2. The level presented represents the 90th percentile of 10 test sites. The action levels for copper and lead were not exceeded at any of the 10 sites tested.
3. Water containing more than 20 mg/l should not be used as a drinking water source by persons on severely restricted sodium diets. Water containing more than 270 mg/l should not be used as a drinking water source by people on moderately restricted diets.
4. The average is based on a Locational Running Annual Average (LRAA) for the four quarters of 2017. The highest LRAA for the TTHM and HAA5 was in the 1st quarter of 2017.

Non-Detects (ND) - laboratory analysis indicates that the constituent is not present.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000. Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Nephelometric Turbidity Unit (NTU) - nephelometric turbidity unit is a measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.

90th Percentile Value- The values reported for lead and copper represent the 90th percentile. A percentile is a value on a scale of 100 that indicates the percent of a distribution that is equal to or below it. The 90th percentile is equal to or greater than 90% of the lead and copper values detected at your water system.

Action Level - the concentration of a contaminant, which, if exceeded, triggers treatment, or other requirements, which a water system must follow.

Treatment Technique (TT) - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

Maximum Contaminant Level - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination.

Locational Running Average (LRAA) - The LRA is calculated by taking the average of the four most recent samples collected at each individual site.

N/A-Not applicable